

ANALYTICAL REPORT
Transmission Electron Microscopy
AHERA Airborne Asbestos Analysis Summary

Method: 40 CFR Part 763

Forensic Analytical Consulting Svcs
 David Justin Brinkerhoff
 7625 Sunrise Blvd. Suite 104
 Citrus Heights, CA 95610

Client Number: SAC02
 Report Number: T029809
 Date Received: 3/28/18
 Date Reported: 3/30/18
 Analyst(s): MNB/MAB

Job ID/PO: PJ29642

Site: Sonoma State University, 1801 E. Cotati Avenue, Rohnert Park CA 94928

Sample Number	Lab Number	Date Collected	Air Volume, liters	Analytical Sensitivity, s/cc	Asbestos Concentration,		Asbestos type(s)* detected
					s/cc	s/mm2	
CR242221	20118903	3/27/18					BL,NA
CR238425	20118904	3/27/18					BL,NA
CR242242	20118905	3/27/18	2185.0	0.0034	<0.0034	<19.2	ND
CR242222	20118906	3/27/18	2034.0	0.0036	<0.0036	<19.2	ND
CR242194	20118907	3/27/18	2070.0	0.0036	<0.0036	<19.2	ND
CR242228	20118908	3/27/18	2090.0	0.0035	<0.0035	<19.2	ND
CR242192	20118909	3/27/18	2052.0	0.0036	<0.0036	<19.2	ND
CR242191	20118910	3/27/18	2004.5	0.0037	<0.0037	<19.2	ND
CR242197	20118911	3/27/18	1928.5	0.0038	<0.0038	<19.2	ND
CR238423	20118912	3/27/18	1719.5	0.0043	<0.0043	<19.2	ND
CR242238	20118913	3/27/18	1611.0	0.0046	<0.0046	<19.2	ND
CR242213	20118914	3/27/18	1584.0	0.0047	<0.0047	<19.2	ND
CR242231	20118915	3/27/18	1548.0	0.0048	<0.0048	<19.2	ND
CR242265	20118916	3/27/18	1624.5	0.0046	<0.0046	<19.2	ND



Mark Floyd, Analytical Microscopy Supervisor

* Asbestos types: CH=chrysotile; AM=amosite; CR=crocidolite; TR=tremolite; AC=actinolite; AN=anthophyllite; ND=none detected; NA=Not Analyzed; n/a=not applicable (i.e., divide by 0); OV=overloaded; BL=blank sample; PF=prepped not analyzed.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any U.S. government agency. Forensic Analytical is unable to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of 30 days, according to all state and federal guidelines, unless otherwise specified.