



1801 East Cotati Avenue
Rohnert Park, CA 94928-3609

FACILITIES MANAGEMENT

707.664.2317 • Fax 707.664.3105

September 19, 2016

Division of Occupational Safety and Health
American Canyon District Office
3419 Broadway Street, Suite H8
American Canyon, CA 94503

SUBJECT: Submittal of Sonoma State University Asbestos Testing for September 2016

Sonoma State University is providing with this letter asbestos testing results for the Month of August 2016 for review and comment. The University has made every effort to implement an effective Asbestos Management Program that meets and exceeds all Cal/OSHA and EPA requirements.

You may find information about SSU's asbestos management program on the University's web site at <http://www.sonoma.edu/ehs/hazmat/asbestos/>.

It is of utmost importance to the University to meet the legal standards for maintaining a safe and hazard-free environment for our campus community. To this end we are forwarding the testing results for your independent review. Please apprise us promptly if any test results we have submitted do not comply with your regulatory standards.

We have completed all identified task specific personal air assessments with all many time below the PCM standard and 10 were non-detect for any asbestos fibers by TEM one result was at the detection level of 15.4 structures per square millimeter and one was 38.5 structures per square millimeter. While both these results or well below the 70 structures per square millimeter clearance for K-12 re-occupancy we will be investigating further. We continue voluntary monthly building air sampling, Communication to employees, and any procedural enhancements identified through the process.

If you have any questions, please do not hesitate to contact me either at my office 707-664-2932 or my cell 707-486-1360.

Sincerely,

A handwritten signature in black ink, appearing to read "Craig Dawson", with a checkmark at the end.

Craig Dawson, CHMM
Director of Energy/ Environmental Health & Safety
Sonoma State University
1801 East Cotati Avenue
Rohnert Park, CA 94928

CD:cd

Enclosure - September COC and Lab Report

THE CALIFORNIA STATE UNIVERSITY

Bakersfield • Channel Islands • Chico • Dominguez Hills • East Bay • Fresno • Fullerton • Humboldt • Long Beach • Los Angeles • Maritime Academy
Monterey Bay • Northridge • Pomona • Sacramento • San Bernardino • San Diego • San Francisco • San Jose • San Luis Obispo • San Marcos • Sonoma • Stanislaus