



ANALYTICAL REPORT
Transmission Electron Microscopy
AHERA Airborne Asbestos Analysis Summary

Method: 40 CFR Part 763

Forensic Analytical Consulting Services
David Justin Brinkerhoff
7625 Sunrise Blvd, Suite 104
Citrus Heights CA 95610

Client Number: SAC02
Report Number: T028346
Date Received: 1/19/17
Date Reported: 1/20/17

P.O. No: _____ Page: 1 of 1
Job ID: PJ29642
Site: Sonoma State University

Sample Number	Lab Number	Date Collected	Air Volume, liters	Analytical Sensitivity, s/cc	Asbestos Concentration, s/cc	Asbestos Concentration, s/mm2	Asbestos type(s) detected*	
29642-0118- 01	20114329	1/18/17	This sample was not prepared or analyzed					
29642-0118- 02	20114330	1/18/17	This sample was not prepared or analyzed					
29642-0118- 03	20114331	1/18/17	1536.0	0.0048	<0.0048	<19.2	ND	
29642-0118- 04	20114332	1/18/17	1536.0	0.0048	<0.0048	<19.2	ND	
29642-0118- 05	20114333	1/18/17	1497.9	0.0049	<0.0049	<19.2	ND	
29642-0118- 06	20114334	1/18/17	1488.0	0.0050	<0.005	<19.2	ND	
29642-0118- 07	20114335	1/18/17	1420.8	0.0042	<0.0042	<15.4	ND	
29642-0118- 08	20114336	1/18/17	1430.4	0.0041	<0.0041	<15.4	ND	
29642-0118- 09	20114337	1/18/17	1363.2	0.0043	<0.0043	<15.4	ND	
29642-0118- 10	20114338	1/18/17	1372.8	0.0043	<0.0043	<15.4	ND	
29642-0118- 11	20114339	1/18/17	1353.6	0.0044	<0.0044	<15.4	ND	
29642-0118- 12	20114340	1/18/17	1411.2	0.0042	<0.0042	<15.4	ND	
29642-0118- 13	20114341	1/18/17	1449.6	0.0041	<0.0041	<15.4	ND	
29642-0118- 14	20114342	1/18/17	1536.0	0.0048	<0.0048	<19.2	ND	

Mark Floyd, Analytical Microscopy Supervisor

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full with approval from Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any U.S. government agency. Forensic Analytical is unable to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of 30 days, according to all state and federal guidelines, unless otherwise specified.

* Asbestos types: CH=chrysotile; AM=amosite; CR=crocidolite; TR=tremolite; AC=actinolite; AN=anthophyllite; ND=none detected

** Air volume is less than the method-specified volume of 1200 L. Extra grid openings analyzed to achieve 0.005 s/cc AS, if needed.